

# Lead and Copper Tap Sample Analysis and Result Ranking

Reporting Format 62-550.730(4)(a)

System Name: Wedgefield

Date Submitted to Lab: 07/20/23

PWS-ID: 3480149

Analysis Date: 07/21/23

Laboratory Name: Benchmark EnviroAnalytical, Inc.

Lab Analysis method: SM3113B

Lab-ID: B84167

Lead or Copper (list one): Lead

Laboratory Contact Person: E. Cameron


Method Detection Limit: 0.00067 mg/L

Phone: (941) 723 - 9986

90th Percentile Value: 0.0020 mg/L

| A | RANK | LOCATION CODE NO. | TIER | LAB SAMPLE ID | DATE SITE SAMPLED | LEAD (mg/L) | COPPER (mg/L) |
|---|------|-------------------|------|---------------|-------------------|-------------|---------------|
|   | 1    | 20525 Majestic    | 3    | 23071091 002  | 07/12/23          | 0.00067 U   |               |
|   | 2    | 20139 Macon       | 1    | 23071091 007  | 07/12/23          | 0.00067 U   |               |
|   | 3    | 2702 Alabaster    | 1    | 23071091 008  | 07/11/23          | 0.00067 U   |               |
|   | 4    | 2718 Abney        | 1    | 23071091 014  | 07/17/23          | 0.00067 U   |               |
|   | 5    | 2505 Abbey        | 1    | 23071091 003  | 07/11/23          | 0.0010 I    |               |
|   | 6    | 20115 Macon       | 1    | 23071091 004  | 07/18/23          | 0.0010 I    |               |
|   | 7    | 20416 Majestic    | 1    | 23071091 005  | 07/14/23          | 0.0010 I    |               |
|   | 8    | 2645 Abney        | 1    | 23071091 006  | 07/11/23          | 0.0010 I    |               |
|   | 9    | 2647 Alabaster    | 1    | 23071091 009  | 07/12/23          | 0.0010 I    |               |
|   | 10   | 2359 Ardon        | 1    | 23071091 010  | 07/11/23          | 0.0010 I    |               |
|   | 11   | 20203 Majestic    | 1    | 23071091 012  | 07/11/23          | 0.0010 I    |               |
|   | 12   | 2536 Abalone      | 1    | 23071091 015  | 07/12/23          | 0.0010 I    |               |
|   | 13   | 2730 Abalone      | 1    | 23071091 018  | 07/19/23          | 0.0010 I    |               |
|   | 14   | 20733 Macon       | 1    | 23071091 019  | 07/19/23          | 0.0010 I    |               |
|   | 15   | 20550 Maxim Pkwy  | 1    | 23071091 020  | 07/20/23          | 0.0010 I    |               |
|   | 16   | 2723 Abbey        | 1    | 23071091 001  | 07/12/23          | 0.0020 I    |               |
|   | 17   | 20201 Macon       | 1    | 23071091 011  | 07/13/23          | 0.0020 I    |               |
|   | 18   | 2639 Alabaster    | 1    | 23071091 013  | 07/13/23          | 0.0020 I    |               |
|   | 19   | 20721 Nettleton   | 1    | 23071091 017  | 07/19/23          | 0.0020 I    |               |
|   | 20   | 2812 Abney        | 1    | 23071091 016  | 07/17/23          | 0.0240 I    |               |

CERTIFICATION. The tap samples used for lead and copper analyses were submitted by the above PWS. Each sample container had one liter of solution ( $\pm 100\text{mL}$ ). All samples were taken properly by the above system and analyzed in accordance with the requirements in subsection 62-550.550(1), F.A.C. The sampling dates were reported for each sample received. I hereby certify that all data submitted are correct.

SIGNATURE OF AUTHORIZED LABORATORY REPRESENTATIVE: 

NAME (Please Print): Kathleen Gauthier/Haley Richardson

TITLE and DATE: QC Officer/QA Officers 08/10/23

# Lead and Copper Tap Sample Analysis and Result Ranking

Reporting Format 62-550.730(4)(a)

System Name: Wedgfield

Date Submitted to Lab: 07/20/23

PWS-ID: 3480149

Analysis Date: 07/21/23

Laboratory Name: Benchmark EnviroAnalytical, Inc.

Lab Analysis method: 200.7

Lab-ID: B84167

Lead or Copper (list one): Copper

Laboratory Contact Person: E. Cameron


Method Detection Limit: 0.004 mg/L

Phone: (941) 723 - 9986

90th Percentile Value: 0.1620 mg/L

| A | RANK | LOCATION CODE NO. | TIER | LAB SAMPLE ID | DATE SITE SAMPLED | LEAD (mg/L) | COPPER (mg/L) |
|---|------|-------------------|------|---------------|-------------------|-------------|---------------|
|   | 1    | 2718 Abney        | 1    | 23071091 014  | 07/17/23          |             | 0.004 U       |
|   | 2    | 20525 Majestic    | 3    | 23071091 002  | 07/12/23          |             | 0.0070 I      |
|   | 3    | 20203 Majestic    | 1    | 23071091 012  | 07/11/23          |             | 0.0090 I      |
|   | 4    | 20416 Majestic    | 1    | 23071091 005  | 07/14/23          |             | 0.0110 I      |
|   | 5    | 2359 Ardon        | 1    | 23071091 010  | 07/11/23          |             | 0.0130 I      |
|   | 6    | 20733 Macon       | 1    | 23071091 019  | 07/19/23          |             | 0.0140 I      |
|   | 7    | 2647 Alabaster    | 1    | 23071091 009  | 07/12/23          |             | 0.0150 I      |
|   | 8    | 20139 Macon       | 1    | 23071091 007  | 07/12/23          |             | 0.0170        |
|   | 9    | 2645 Abney        | 1    | 23071091 006  | 07/11/23          |             | 0.0180        |
|   | 10   | 20721 Nettleton   | 1    | 23071091 017  | 07/19/23          |             | 0.0180        |
|   | 11   | 2730 Abalone      | 1    | 23071091 018  | 07/19/23          |             | 0.0180        |
|   | 12   | 20201 Macon       | 1    | 23071091 011  | 07/13/23          |             | 0.0260        |
|   | 13   | 20115 Macon       | 1    | 23071091 004  | 07/18/23          |             | 0.0330        |
|   | 14   | 2536 Abalone      | 1    | 23071091 015  | 07/12/23          |             | 0.0470        |
|   | 15   | 2702 Alabaster    | 1    | 23071091 008  | 07/11/23          |             | 0.0660        |
|   | 16   | 2639 Alabaster    | 1    | 23071091 013  | 07/13/23          |             | 0.0920        |
|   | 17   | 2812 Abney        | 1    | 23071091 016  | 07/17/23          |             | 0.1540        |
|   | 18   | 2505 Abbey        | 1    | 23071091 003  | 07/11/23          |             | 0.1620        |
|   | 19   | 20550 Maxim Pkwy  | 1    | 23071091 020  | 07/20/23          |             | 0.1880        |
|   | 20   | 2723 Abbey        | 1    | 23071091 001  | 07/12/23          |             | 0.1970        |

CERTIFICATION. The tap samples used for lead and copper analyses were submitted by the above PWS. Each sample container had one liter of solution ( $\pm 100\text{mL}$ ). All samples were taken properly by the above system and analyzed in accordance with the requirements in subsection 62-550.550(1), F.A.C. The sampling dates were reported for each sample received. I hereby certify that all data submitted are correct.

SIGNATURE OF AUTHORIZED LABORATORY REPRESENTATIVE: 

NAME (Please Print): Kathleen Gauthier / Haley Richardson

TITLE and DATE: QC Officer/OA Officers 08/21/23