



# PLURIS

## HAMPSTEAD

Property Address: \_\_\_\_\_

Builder Initials	Gravity Connection	Pluris Check
	Landscaping to be installed on level final grade, including sod or softscapes and outside of drainage swells.	
	Line to be connect from property side to utility side.	
	*Elder valve installed, glued in, cut to grade, capped, and is visible with concrete donut installed. Cast iron sleeves may be used within concrete driveways or sidewalks only.	
	*Clean out installed, glued in, cut to grade, capped, and is visible with concrete donut installed. Cast iron sleeves may be used within concrete driveways or sidewalks only.	
	Lines must be clear of any debris and verified there is no standing water in pipe. Any and all debris must be removed from lines, no debris may be made tributary to gravity mains.	
	Photo of the cleanout and elder valve in relation to the home sent to: <a href="mailto:permitting@plurisusa.com">permitting@plurisusa.com</a> Any photos submitted that do not meet checklist requirements will be processed as a failed inspection.	
	*Order of install — elder valve, clean out, street (c/o & e/v must be located in the utility easement)	

*\* THE UNDERSIGNED CONFIRMS THAT ALL ITEMS ABOVE ARE COMPLETED AND CORRECT*

Builder Signature: \_\_\_\_\_

<u>PLURIS OFFICE USE ONLY</u>		
PASS / FAIL		DATE
_____	Pluris Signature: _____	_____