

PLURIS HAMPSTEAD
Residential

PROPERTY ADDRESS:

Builder Check	Gravity Connection	Pluris Check
	Landscaping to be installed on level final grade, including sod, soft scapes, driveways and sidewalks.	
	Line to be connect from property side to utility side.	
	*Elder valve must be installed. Elder valve caps must be glued in, cut to grade, a minimum of 6 inches above final grade and must have a 4-inch screw-in cap with a concrete donut. Elder valve within the driveway or sidewalk must use a cast iron sleeve with a 6-to-11-inch air gap.	
	*Clean out must be installed. Clean out caps must be glued in, cut to grade, a minimum of 6 inches above final grade and must have a 4-inch screw-in cap with a concrete donut. Clean out within the driveway or sidewalk must use a cast iron sleeve with a 6-to-11-inch air gap.	
	All lines must be clear of any debris and no standing water in elder valve or clean out. All debris must be removed by builder. No debris including grit and sand, shall be made tributary to the gravity main.	
	Photo of the cleanout and elder valve in relation to the home sent to permitting@plurisusa.com . Any photos submitted that do not meet checklist requirements will be processed as a failed inspection.	
	*Elder valve and Clean out must be outside of all swells and drainage areas and located in the utility easement.	

*** THE UNDERSIGNED CONFIRMS THAT ALL ITEMS ABOVE ARE COMPLETED AND CORRECT**

Builder Signature: _____

Pluris office use only

Pass / Fail

Date

Pluris Signature: _____